TOWER 2
TOWER
PATH TUBE
PULL AND OFFSET (PULL BOX 'W') AT TOWER 2 CORE WALL SEE DETAIL '8' DWG. E6-.03
4"-5" C. ENCASED IN 2" CONCRETE
4"-5" CONDUITS IN 2" CONCRETE FLOOR ENVELOPE WITHOUT CONCRETE ENVELOPE SEE NOTE 12.
4"-5" CONDUITS IN 2" CONCRETE FLOOR ENVELOPE WITH DUCT BANK TUNNEL SEE NOTE 10.
15KV CABLE PULL AND TERMINATION CLOSET
SEE NOTE 13 FOR CONTINUATION SEE DWG. E-4.03
UP TO NORTH P1 SEE NOTE 8
DN TO TOWER P1 SEE NOTE 8
FIXED BOX, IPSOC HUNG CEILING BETWEEN BEAMS
2-5" CONDUIT ENCASED IN 2" CONCRETE BETWEEN HUNG CEILING CUTTS
2-5" CONDUIT TO EMERGENCY GENERATOR FROM TOWER 2 SEE DWG. E5.01 FOR PLANS